



Energy Demand Reduction for FSU's Central Utility Plant

Group members: Edgardo Cordero, Alec Schoengrund, Steven Decker,
Mira Meyers, Keaton Zargham, and Juan Villalobos

Team 521 Introductions



Juan Villalobos
Energy Auditor



Alec Schoengrund
Mechanical Design Engineer



Mira Meyers
Quality Control Engineer



Keaton Zargham
Data Analyst



Edgardo Cordero
Project Manager



Steven Decker
HVAC Engineer

Juan Villalobos



Sponsor and Advisor



Engineering Mentor
Cameron Griffith
*Solutions Advisor, LEED AP,
CEM, CDSM*



Academic Advisor
Dr. Juan Ordonez, Ph.D.
*Professor of Thermodynamic Optimization
for Advanced Energy Systems*

Juan Villalobos

Objective

To research, study, evaluate, and propose a project that reduces FSU Facility's Electric Utility bill by reducing peak demand and/or the overall electric consumption to generate a financial payback to FSU.


Juan Villalobos



FSU Energy Overview


Average Monthly Energy Usage (2019):

- Consumption (kWh). **13,500,000**
- Demand (kW). **24,500**



Electric Utility Rate Structure (2019):

- Consumption (\$/kWh). **0.049**
- Demand (\$/kW). **11.32**



Average Monthly Energy Bill (2019):


- Consumption (\$). **660,000**
- Demand (\$). **280,000**

Juan Villalobos



HVAC System

- Over **50%** of energy spend is from heating, ventilation, and cooling systems on campus
- FSU relies on **21** chillers to cool campus buildings
- Chillers produce cold water that is pumped around campus to air handling units to supply cold air to buildings
- The compressors of the chillers, as well as the fans and pumps consume large amounts of electricity to operate



Juan Villalobos

HVAC System

- Capacity of AC units are measured in Tons
- The **6** chillers in the Central Utility Plant are **1,200** tons each
- Typical load on the CUP during a hot summer day is between **2,990** and **4,660** tons
- Current operating efficiency of the CUP is **0.69 [kW/ton]**



Calculating Demand Charge

- $4,660 \text{ [tons]} * 0.69 \text{ [kW/ton]} = 3,215 \text{ [kW]} * 11.32 \text{ [$/kW]} = \mathbf{\$36,400}$


Calculating Consumption Charge

- $3,850 \text{ [avg tons]} * 0.69 \text{ [kW/ton]} * 720 \text{ [hours]} = 1,900,000 \text{ [kWh]} * 0.049 \text{ [$/kWh]} = \mathbf{\$93,700}$

Juan Villalobos

Thermal Energy Storage Tanks


Current Peak Demand = 7,500 kW = \$85,000



Difference of 6,500 kW between Peak and Off-Peak Energy Demand


Alec Schoengrund

Thermal Energy Storage Tanks



Alec Schoengrund

Thermal Energy Storage Tanks



Alec Schoengrund

Tank Composition

Stratified TES main structure

- Steel, concrete, and plastic


Diffusers

- Warm and chilled water enter and exit the tank through diffusers
- Coated steel piping
- Key to thermocline
- Spreads radially to reduce heat transfer between the hot and cold bodies of water.

Insulation Material

- Polyurethane foam, mineral, wool
- Assists with maintaining temperature



Service life: > 50 years



Alec Schoengrund

Tank Efficiency


- Thermal efficiency is 90%
- Dependent on stratification, thermocline, and insulation
- Insulation Methods
 1. Spray on polyurethane foam
 2. Injecting insulation between structural layers
 3. Mineral wool, fiber glass, or ceramic fiber used as external wrap.
- Running the chillers at night when the ambient temperature is lower will improve the Chillers' efficiency



Alec Schoengrund

Tank Sizing

- 7,300 [gpm] flow rate of CUP * 8-hour cycle = 3.5M Gallons required
- Larger height is more efficient
- Environment constrains the diameter more than the height
- 100 ft of available space behind the C.U.P
- Height would have to be 51 feet (a little less than a 4-story building)
- System schematics and energy balance is currently being researched to provide accurate dimensions and validation for the tank.
- Most efficient TES Tank would be 50 ft wide and 250 ft tall
- We will be more practical; our tank will be 100 ft wide and 50 ft tall



Alec Schoengrund

Project Comparison



• Project Cost	6,000,000 [\$]
• Tank Size:	3M [gal]
• Cooling Capacity:	26,200 [ton-hours]
• Chilled Water Flow Rate:	8,300 [gpm]
• Peak Electric Load Reduction:	3,000 [kW]
• Demand Rate:	9.50 [\$/kW]
• On-Peak Consumption Rate:	7.002 [¢/kWh]
• Off-Peak Consumption Rate:	5.170 [¢/kWh]
• Annual Savings:	700,000 [\$]
• Demand Charge Savings:	340,000 [\$]
• Consumption Charge Savings:	360,000 [\$]



FSU

• Project Cost:	6,470,000 [\$]
• Tank Size:	3.5M [gal]
• Cooling Capacity:	30,800 [ton-hours]
• Chilled Water Flow Rate:	7,366 [gpm]
• Peak Electric Load Reduction:	3,215 [kW]
• Demand Rate:	11.32 [\$/kW]
• Flat Consumption Rate:	4.9 [¢/kWh]
• Annual Projected Savings:	400,000 [\$]
• Demand Charge Savings:	350,000 [\$]

Mira Meyers



Project Logistics



Mira Meyers

Project Financials

- \$6.5M Total Project Cost / \$400,000 Annual Savings = 16-year ROI
 - Study from Texas A&M supports the team's sizing and assumptions

Tank (M gal)	Annual billing cost savings (\$)	Annual cost savings percentage	Annual energy cost savings (\$)	Annual demand cost savings (\$)	Total elec. consumption reduction (kWh)	Demand reduction (kW)	Annual cooling increase (ton-hr)
1.0	\$ 471,298	10.1%	\$ 223,536	\$ 247,762	2,863,909	2059	6,007,818
2.0	\$ 627,097	13.5%	\$ 240,909	\$ 386,188	2,688,822	3127	6,051,099
3.0	\$ 798,285	17.1%	\$ 256,078	\$ 542,207	2,478,769	4345	6,094,219
3.5	\$ 907,231	19.5%	\$ 264,109	\$ 643,121	2,377,427	5036	6,114,129
4.0	\$ 912,437	19.6%	\$ 269,598	\$ 642,838	2,326,156	5036	6,123,930
5.0	\$ 922,487	19.8%	\$ 280,153	\$ 642,335	2,211,959	5036	6,144,385
6.0	\$ 932,876	20.0%	\$ 290,422	\$ 642,454	2,095,404	5036	6,164,696
7.0	\$ 940,319	20.2%	\$ 297,746	\$ 642,573	2,008,835	5036	6,180,300

Mira Meyers

Budget Report

- Budget: \$2000
- Spent: \$0
- Budget will be used for our Engineering day demonstration
- Projected total cost: \$158.00

Product	Quantity	Cost
Arduino	1	\$18
Arduino cable	1	\$6
8 Channel Relay Module	2	\$20
Breadboard Jumper Wires	1	\$7
LED Light Strip	1	\$20
LCD Counter Displays	4	\$40
6-pack of LED Lightbulbs	2	\$20
6-pack of E26 Sockets	2	\$27

Mira Meyers



Demonstration



- Current system demonstration present at the National High Magnetic Field Laboratory
- The team will attempt to create a demonstration that resembles their system but redesigned to our needs

Mira Meyers

Conclusion

- FSU spends more than 20 million per year on electric utilities (Over 50% is from HVAC)
- Thermal energy storage reduces cost by running chillers at night when electricity is cheaper
- Implementation of tank would cost \$6.5M and provide an annual savings of \$400,000 with an ROI of 16 years
- UCF is currently working towards a 2nd TES Tank project because of the success they have had with 1st Tank

Mira Meyers



Questions?



Team Members:

Email:

Edgardo Cordero

edc15@my.fsu.edu

Steven Decker

sd16b@my.fsu.edu

Alec Schoengrund

abs16d@my.fsu.edu

Mira Meyers

mam15x@my.fsu.edu

Keaton Zargham

ksz17@my.fsu.edu

Juan Villalobos

jjv15b@my.fsu.edu

References

- Lew, J. T. V. (n.d.). Effect of the ratio of tank height/diameter on the thermal storage efficiency. Retrieved March 2, 2020, from https://www.researchgate.net/figure/Effect-of-the-ratio-of-tank-height-diameter-on-the-thermal-storage-efficiency-while_fig10_267154195
- Zhang, Z., Turner, W. D., Chen, Q., Xu, C., & Deng, S. (2011). Tank size and operating strategy optimization of a stratified chilled water storage system. *Applied Thermal Engineering*, 31(14-15), 2656–2664. doi: 10.1016/j.applthermaleng.2011.04.035
- Energy Efficiency On Demand - DN Tanks. (n.d.). Retrieved March 2, 2020, from <https://dntanks.com/wp-content/uploads/2016/07/DNTanks-TES-Brochure-2013.pdf>
- Strata-Therm® Stratified Water Thermal Energy Storage – McDermott Engineering retrieved February 26, 2020 <https://www.mcdermott.com/getmedia/9c1b9e3f-b58b-47b9-97b0-44c5b7398a44/Strata-Therm-v9-3-digital.aspx>
- Lower Cooling Cost. (n.d.). Retrieved February 26, 2020, from <http://www.calmac.com/lower-cooling-costs>
- Hartman, T. (201AD). All-Variable Speed Centrifugal Chiller Plants. *ASHRAE JOURNAL*, 43–51. Retrieved from https://triangleashrae.com/images/meeting/111616/Meeting_Presentations/all_variable_speed_centrifugal_chiller_plants_journal_2001_09_thomas_hartman_.pdf